

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

02-January-2026

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:


Date Rec. : 29 December 2025
LR Report: CA21316-DEC25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	30-Dec-25	30-Dec-25	30-Dec-25
2: Analysis Start Time		---	---	14:10	14:10	13:35
3: Analysis Completed Date		---	---	02-Jan-26	02-Jan-26	02-Jan-26
4: Analysis Completed Time		---	---	10:21	10:21	10:21
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	29-Dec-25 09:47	5.9	1.81	0	0	10
7: DW DW-East Whitechurch DW-SS	29-Dec-25 09:34	5.9	1.07	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


 Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

29-December-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 22 December 2025
LR Report: CA21106-DEC25**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	23-Dec-25	23-Dec-25	23-Dec-25
2: Analysis Start Time		---	---	15:30	15:30	15:10
3: Analysis Completed Date		---	---	29-Dec-25	29-Dec-25	29-Dec-25
4: Analysis Completed Time		---	---	10:58	10:58	10:58
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	22-Dec-25 08:08	3.9	1.52	0	0	< 10
7: DW DW-East Whitechurch DW-SS	22-Dec-25 07:55	3.9	1.74	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

19-December-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 16 December 2025
LR Report: CA20844-DEC25**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				17-Dec-25	17-Dec-25	17-Dec-25
2: Analysis Start Time				16:35	16:35	16:10
3: Analysis Completed Date				19-Dec-25	19-Dec-25	19-Dec-25
4: Analysis Completed Time				14:56	14:56	14:56
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	16-Dec-25 08:35	2.6	1.45	0	0	< 10
7: DW DW-East Whitechurch DW-SS	16-Dec-25 08:20	2.6	1.45	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

12-December-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 09 December 2025
LR Report: CA20509-DEC25**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	10-Dec-25	10-Dec-25	10-Dec-25
2: Analysis Start Time		---	---	10:45	10:45	10:05
3: Analysis Completed Date		---	---	12-Dec-25	12-Dec-25	12-Dec-25
4: Analysis Completed Time		---	---	10:40	10:40	10:40
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	09-Dec-25 08:44	0.2	1.87	0	0	< 10
7: DW DW-East Whitechurch DW-SS	09-Dec-25 08:22	0.2	1.82	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

05-December-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 02 December 2025
LR Report: CA20187-DEC25**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	03-Dec-25	03-Dec-25	03-Dec-25
2: Analysis Start Time		---	---	13:50	13:50	13:00
3: Analysis Completed Date		---	---	05-Dec-25	05-Dec-25	05-Dec-25
4: Analysis Completed Time		---	---	11:43	11:43	11:43
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	02-Dec-25 08:32	2.3	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	02-Dec-25 08:35	2.3	---	0	0	---
8: TW TW-Whitechurch TW	02-Dec-25 08:26	2.3	1.90	0	0	10
9: DW DW-East Whitechurch DW-SS	02-Dec-25 08:45	2.3	2.11	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

28-November-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 25 November 2025
LR Report: CA21235-NOV25

Copy: #1


CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	26-Nov-25	26-Nov-25	26-Nov-25
2: Analysis Start Time		---	---	15:40	15:40	15:05
3: Analysis Completed Date		---	---	28-Nov-25	28-Nov-25	28-Nov-25
4: Analysis Completed Time		---	---	13:54	13:54	13:54
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	25-Nov-25 08:45	6.3	1.58	0	0	< 10
7: DW DW-East Whitechurch DW-SS	25-Nov-25 08:35	6.3	1.29	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

21-November-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 18 November 2025
LR Report: CA20867-NOV25

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	19-Nov-25	19-Nov-25	19-Nov-25
2: Analysis Start Time		---	---	10:15	10:15	09:55
3: Analysis Completed Date		---	---	21-Nov-25	21-Nov-25	21-Nov-25
4: Analysis Completed Time		---	---	10:51	10:51	10:51
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	17-Nov-25 15:06	2.9	1.70	0	0	< 10
7: DW DW-East Whitechurch DW-SS	17-Nov-25 15:01	2.9	1.31	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

17-November-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban


Date Rec. : 12 November 2025
LR Report: CA20596-NOV256242 Fallon Drive
Lucan, ON
N0M 2J0, Canada**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	13-Nov-25	13-Nov-25	13-Nov-25
2: Analysis Start Time		---	---	13:30	13:30	12:10
3: Analysis Completed Date		---	---	17-Nov-25	17-Nov-25	17-Nov-25
4: Analysis Completed Time		---	---	10:38	10:38	10:38
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	12-Nov-25 08:21	4.0	1.68	0	0	< 10
7: DW DW-East Whitechurch DW-SS	12-Nov-25 08:09	4.0	1.29	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

07-November-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 04 November 2025
LR Report: CA20222-NOV25**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Nov-25	05-Nov-25	05-Nov-25
2: Analysis Start Time		---	---	09:45	09:45	09:10
3: Analysis Completed Date		---	---	07-Nov-25	07-Nov-25	07-Nov-25
4: Analysis Completed Time		---	---	11:18	11:18	11:18
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	03-Nov-25 15:10	4.6	2.07	0	0	< 10
7: DW DW-East Whitechurch DW-SS	03-Nov-25 14:55	4.6	1.36	0	0	< 10
8: RW RW1-Whitechurch RW-Well 1	03-Nov-25 15:08	4.6	---	0	0	---
9: RW RW2-Whitechurch RW-Well 2	03-Nov-25 15:16	4.6	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

07-November-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 04 November 2025
LR Report: CA20223-NOV25**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Nov-25	05-Nov-25	05-Nov-25
2: Analysis Start Time		---	---	09:45	09:45	09:10
3: Analysis Completed Date		---	---	07-Nov-25	07-Nov-25	07-Nov-25
4: Analysis Completed Time		---	---	11:18	11:18	11:18
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	04-Nov-25 11:54	4.6	1.81	0	0	< 10
7: DW DW-East Whitechurch DW-SS	04-Nov-25 11:26	4.6	1.73	0	0	< 10
8: DW DW-North Whitechurch DW-SS	04-Nov-25 12:12	4.6	1.76	0	0	< 10
9: RW RW1-Whitechurch RW-Well 1	04-Nov-25 11:41	4.6	---	0	0	---
10: RW RW2-Whitechurch RW-Well 2	04-Nov-25 11:49	4.6	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

03-November-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Date Rec. : 28 October 2025
LR Report: CA21469-OCT25

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:


CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				29-Oct-25	29-Oct-25	29-Oct-25
2: Analysis Start Time				09:30	09:30	09:15
3: Analysis Completed Date				31-Oct-25	31-Oct-25	31-Oct-25
4: Analysis Completed Time				11:57	11:57	11:57
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	27-Oct-25 14:19	5.1	2.19	0	0	< 10
7: DW DW-East Whitechurch DW-SS	27-Oct-25 14:12	5.1	1.37	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Carrie Greenlaw
 Project Specialist,
 Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

27-October-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:


Date Rec. : 21 October 2025
LR Report: CA21154-OCT25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				22-Oct-25	22-Oct-25	22-Oct-25
2: Analysis Start Time				16:30	16:30	16:00
3: Analysis Completed Date				24-Oct-25	24-Oct-25	24-Oct-25
4: Analysis Completed Time				13:43	13:43	13:43
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	21-Oct-25 08:19	9.4	2.06	0	0	< 10
7: DW DW-East Whitechurch DW-SS	21-Oct-25 08:06	9.4	1.54	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

17-October-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 14 October 2025
LR Report: CA20679-OCT256242 Fallon Drive
Lucan, ON
N0M 2J0, Canada**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				15-Oct-25	15-Oct-25	15-Oct-25
2: Analysis Start Time				13:45	13:45	12:50
3: Analysis Completed Date				17-Oct-25	17-Oct-25	17-Oct-25
4: Analysis Completed Time				11:47	11:47	11:47
5: MAC	---	---	---	0	0	---
6: TW TW-Whitechurch TW	14-Oct-25 08:38	8.9	1.95	0	0	< 10
7: DW DW-East Whitechurch DW-SS	14-Oct-25 08:24	8.9	1.33	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

14-October-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban


Date Rec. : 07 October 2025
LR Report: CA20399-OCT256242 Fallon Drive
Lucan, ON
N0M 2J0, Canada**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				08-Oct-25	08-Oct-25	08-Oct-25
2: Analysis Start Time				10:55	10:55	10:20
3: Analysis Completed Date				10-Oct-25	10-Oct-25	10-Oct-25
4: Analysis Completed Time				10:37	10:37	10:37
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	07-Oct-25 08:22	8.4	1.65	0	0	< 10
7: DW DW-East Whitechurch DW-SS	07-Oct-25 08:11	8.4	1.34	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

06-October-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 01 October 2025
LR Report: CA20051-OCT25**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	02-Oct-25	02-Oct-25	02-Oct-25
2: Analysis Start Time		---	---	10:55	10:55	10:15
3: Analysis Completed Date		---	---	06-Oct-25	06-Oct-25	06-Oct-25
4: Analysis Completed Time		---	---	09:49	09:49	09:49
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	01-Oct-25 08:15	13.6	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	01-Oct-25 08:18	13.6	---	0	0	---
8: TW TW-Whitechurch TW	01-Oct-25 08:13	13.6	1.93	0	0	< 10
9: DW DW-East Whitechurch DW-SS	01-Oct-25 07:58	13.6	1.26	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

26-September-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 23 September 2025
LR Report: CA21391-SEP25

Copy: #1

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				24-Sep-25	24-Sep-25	24-Sep-25
2: Analysis Start Time				14:30	14:30	12:45
3: Analysis Completed Date				26-Sep-25	26-Sep-25	26-Sep-25
4: Analysis Completed Time				12:20	12:20	12:20
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	23-Sep-25 08:17	13.5	2.19	0	0	< 10
7: DW DW-East Whitechurch DW-SS	23-Sep-25 08:02	13.5	1.53	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

22-September-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:


Date Rec. : 16 September 2025
LR Report: CA21025-SEP25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				17-Sep-25	17-Sep-25	17-Sep-25
2: Analysis Start Time				11:20	11:20	10:30
3: Analysis Completed Date				19-Sep-25	19-Sep-25	19-Sep-25
4: Analysis Completed Time				11:59	11:59	11:59
5: MAC	---	---	---	0	0	---
6: TW TW-Whitechurch TW	16-Sep-25 08:08	5.4	2.06	0	0	< 10
7: DW DW-East Whitechurch DW-SS	16-Sep-25 07:57	5.4	1.40	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

12-September-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Date Rec. : 09 September 2025
LR Report: CA20574-SEP25

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:


CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	10-Sep-25	10-Sep-25	10-Sep-25
2: Analysis Start Time		---	---	09:30	09:30	09:20
3: Analysis Completed Date		---	---	12-Sep-25	12-Sep-25	12-Sep-25
4: Analysis Completed Time		---	---	09:49	09:49	09:49
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	08-Sep-25 12:27	8.6	2.12	0	0	< 10
7: DW DW-East Whitechurch DW-SS	08-Sep-25 12:15	8.6	1.12	0	0	10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

05-September-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 02 September 2025
LR Report: CA20092-SEP25

Copy: #1

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				03-Sep-25	03-Sep-25	03-Sep-25
2: Analysis Start Time				14:10	14:10	13:55
3: Analysis Completed Date				05-Sep-25	05-Sep-25	05-Sep-25
4: Analysis Completed Time				13:31	13:31	13:31
5: MAC	---	---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	02-Sep-25 08:40	16.0	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	02-Sep-25 09:06	16.0	---	0	0	---
8: TW TW-Whitechurch TW	02-Sep-25 09:00	16.0	1.36	0	0	< 10
9: DW DW-East Whitechurch DW-SS	02-Sep-25 08:28	16.0	1.34	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

29-August-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

Date Rec. : 26 August 2025
LR Report: CA21516-AUG25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	27-Aug-25	27-Aug-25	27-Aug-25
2: Analysis Start Time		---	---	13:50	13:50	13:20
3: Analysis Completed Date		---	---	29-Aug-25	29-Aug-25	29-Aug-25
4: Analysis Completed Time		---	---	14:25	14:25	14:25
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	26-Aug-25 08:37	10.4	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	26-Aug-25 08:41	10.4	---	0	0	---
8: TW TW-Whitechurch TW	26-Aug-25 08:49	10.4	1.49	0	0	< 10
9: DW DW-East Whitechurch DW-SS	26-Aug-25 08:19	10.4	1.12	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

22-August-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 19 August 2025
LR Report: CA21118-AUG25**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	20-Aug-25	20-Aug-25	20-Aug-25
2: Analysis Start Time		---	---	15:30	15:30	14:45
3: Analysis Completed Date		---	---	22-Aug-25	22-Aug-25	22-Aug-25
4: Analysis Completed Time		---	---	13:19	13:19	13:19
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	19-Aug-25 08:29	6.0	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	19-Aug-25 08:35	6.0	---	0	0	---
8: TW TW-Whitechurch TW	19-Aug-25 08:39	6.0	1.45	0	0	< 10
9: DW DW-East Whitechurch DW-SS	19-Aug-25 08:17	6.0	1.26	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

18-August-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 12 August 2025
LR Report: CA20720-AUG25

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				13-Aug-25	13-Aug-25	13-Aug-25
2: Analysis Start Time				17:10	17:10	15:55
3: Analysis Completed Date				15-Aug-25	15-Aug-25	15-Aug-25
4: Analysis Completed Time				16:10	16:10	16:10
5: MAC	---	---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	12-Aug-25 09:01	5.4	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	12-Aug-25 09:11	5.4	---	0	0	---
8: TW TW-Whitechurch TW	12-Aug-25 09:08	5.4	1.40	0	0	< 10
9: DW DW-East Whitechurch DW-SS	12-Aug-25 08:46	5.4	1.13	0	0	10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

08-August-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 05 August 2025
LR Report: CA20137-AUG25

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	06-Aug-25	06-Aug-25	06-Aug-25
2: Analysis Start Time		---	---	12:40	12:40	12:15
3: Analysis Completed Date		---	---	08-Aug-25	08-Aug-25	08-Aug-25
4: Analysis Completed Time		---	---	11:15	11:15	11:15
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	05-Aug-25 08:41	12.3	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	05-Aug-25 08:26	12.3	---	0	0	---
8: TW TW-Whitechurch TW	05-Aug-25 08:31	12.3	1.32	0	0	< 10
9: DW DW-East Whitechurch DW-SS	05-Aug-25 08:18	12.3	1.11	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

25-July-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

Date Rec. : 22 July 2025
LR Report: CA21292-JUL25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	23-Jul-25	23-Jul-25	23-Jul-25
2: Analysis Start Time		---	---	13:15	13:15	12:10
3: Analysis Completed Date		---	---	25-Jul-25	25-Jul-25	25-Jul-25
4: Analysis Completed Time		---	---	12:14	12:14	12:14
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	22-Jul-25 08:24	7.7	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	22-Jul-25 08:31	7.7	---	0	0	---
8: TW TW-Whitechurch TW	22-Jul-25 08:33	7.7	1.16	0	0	< 10
9: DW DW-East Whitechurch DW-SS	22-Jul-25 08:14	7.7	1.10	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

18-July-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 15 July 2025
LR Report: CA20922-JUL25**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:


CERTIFICATE OF ANALYSIS
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	16-Jul-25	16-Jul-25	16-Jul-25
2: Analysis Start Time		---	---	13:35	13:35	13:15
3: Analysis Completed Date		---	---	18-Jul-25	18-Jul-25	18-Jul-25
4: Analysis Completed Time		---	---	12:19	12:19	12:19
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	15-Jul-25 09:11	11.8	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	15-Jul-25 09:18	11.8	---	0	0	---
8: TW TW-Whitechurch TW	15-Jul-25 09:20	11.8	1.28	0	0	< 10
9: DW DW-East Whitechurch DW-SS	15-Jul-25 09:03	11.8	1.08	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

14-July-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 08 July 2025
LR Report: CA20529-JUL25**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				09-Jul-25	09-Jul-25	09-Jul-25
2: Analysis Start Time				15:50	15:50	15:05
3: Analysis Completed Date				11-Jul-25	11-Jul-25	11-Jul-25
4: Analysis Completed Time				13:27	13:27	13:27
5: MAC	---	---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	08-Jul-25 11:03	10.5	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	08-Jul-25 10:54	10.5	---	0	0	---
8: TW TW-Whitechurch TW	08-Jul-25 11:04	10.5	1.33	0	0	< 10
9: DW DW-East Whitechurch DW-SS	08-Jul-25 10:47	10.5	1.03	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

07-July-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 02 July 2025
LR Report: CA20109-JUL25**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:


CERTIFICATE OF ANALYSIS
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				03-Jul-25	03-Jul-25	03-Jul-25
2: Analysis Start Time				16:40	16:40	16:05
3: Analysis Completed Date				07-Jul-25	07-Jul-25	07-Jul-25
4: Analysis Completed Time				11:14	11:14	11:14
5: MAC	---	---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	02-Jul-25 09:08	14.5	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	02-Jul-25 09:00	14.5	---	0	0	---
8: TW TW-Whitechurch TW	02-Jul-25 09:01	14.5	1.28	0	0	< 10
9: DW DW-East Whitechurch DW-SS	02-Jul-25 08:24	14.5	1.14	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

30-June-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 24 June 2025
LR Report: CA21545-JUN25**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				25-Jun-25	25-Jun-25	25-Jun-25
2: Analysis Start Time				15:30	15:30	14:50
3: Analysis Completed Date				27-Jun-25	27-Jun-25	27-Jun-25
4: Analysis Completed Time				14:57	14:57	14:57
5: MAC	---	---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	24-Jun-25 08:12	14.9	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	24-Jun-25 08:23	14.9	---	0	0	---
8: TW TW-Whitechurch TW	24-Jun-25 08:28	14.9	1.46	0	0	< 10
9: DW DW-East Whitechurch DW-SS	24-Jun-25 07:59	14.9	1.10	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

23-June-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:


Date Rec. : 17 June 2025
LR Report: CA21148-JUN25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				18-Jun-25	18-Jun-25	18-Jun-25
2: Analysis Start Time				16:50	16:50	16:20
3: Analysis Completed Date				20-Jun-25	20-Jun-25	20-Jun-25
4: Analysis Completed Time				17:55	17:55	17:55
5: MAC	---	---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	17-Jun-25 08:23	10.8	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	17-Jun-25 08:36	10.8	---	0	0	---
8: TW TW-Whitechurch TW	17-Jun-25 08:24	10.8	1.18	0	0	< 10
9: DW DW-East Whitechurch DW-SS	17-Jun-25 08:04	10.8	1.13	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

13-June-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Date Rec. : 10 June 2025
LR Report: CA20730-JUN25

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	11-Jun-25	11-Jun-25	11-Jun-25
2: Analysis Start Time		---	---	13:40	13:40	13:10
3: Analysis Completed Date		---	---	13-Jun-25	13-Jun-25	13-Jun-25
4: Analysis Completed Time		---	---	12:05	12:05	12:05
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	10-Jun-25 08:39	12.4	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	10-Jun-25 08:50	12.4	---	0	0	---
8: TW TW-Whitechurch TW	10-Jun-25 08:35	12.4	1.77	0	0	< 10
9: DW DW-East Whitechurch DW-SS	10-Jun-25 08:25	12.4	1.19	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

09-June-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 03 June 2025
LR Report: CA20269-JUN25**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				04-Jun-25	04-Jun-25	04-Jun-25
2: Analysis Start Time				15:50	15:50	15:25
3: Analysis Completed Date				06-Jun-25	06-Jun-25	06-Jun-25
4: Analysis Completed Time				14:20	14:20	14:20
5: MAC	---	---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	03-Jun-25 10:37	11.0	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	03-Jun-25 10:46	11.0	---	0	0	---
8: TW TW-Whitechurch TW	03-Jun-25 10:47	11.0	1.78	0	0	< 10
9: DW DW-East Whitechurch DW-SS	03-Jun-25 10:25	11.0	1.12	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

30-May-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 27 May 2025
LR Report: CA21539-MAY25

Copy: #1

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				28-May-25	28-May-25	28-May-25
2: Analysis Start Time				13:05	13:05	12:20
3: Analysis Completed Date				30-May-25	30-May-25	30-May-25
4: Analysis Completed Time				14:26	14:26	14:26
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	27-May-25 08:12	8.6	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	27-May-25 08:25	8.6	---	0	0	---
8: TW TW-Whitechurch TW	27-May-25 08:11	8.6	1.33	0	0	< 10
9: DW DW-East Whitechurch DW-SS	27-May-25 08:05	8.6	1.11	0	0	10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

26-May-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 20 May 2025
LR Report: CA21044-MAY25

Copy: #1


CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				21-May-25	21-May-25	21-May-25
2: Analysis Start Time				13:30	13:30	13:05
3: Analysis Completed Date				23-May-25	23-May-25	23-May-25
4: Analysis Completed Time				16:05	16:05	16:05
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	20-May-25 08:42	12.7	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	20-May-25 08:49	12.7	---	0	0	---
8: TW TW-Whitechurch TW	20-May-25 09:03	12.7	1.49	0	0	< 10
9: DW DW-East Whitechurch DW-SS	20-May-25 08:25	12.7	1.24	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

20-May-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 13 May 2025
LR Report: CA20778-MAY25

Copy: #1

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				14-May-25	14-May-25	14-May-25
2: Analysis Start Time				16:10	16:10	15:50
3: Analysis Completed Date				16-May-25	16-May-25	16-May-25
4: Analysis Completed Time				15:53	15:53	15:53
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	13-May-25 08:19	11.9	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	13-May-25 08:38	11.9	---	0	0	---
8: TW TW-Whitechurch TW	13-May-25 08:16	11.9	1.44	0	0	< 10
9: DW DW-East Whitechurch DW-SS	13-May-25 08:07	11.9	1.11	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

09-May-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 06 May 2025
LR Report: CA20327-MAY25**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				07-May-25	07-May-25	07-May-25
2: Analysis Start Time				15:45	15:45	15:20
3: Analysis Completed Date				09-May-25	09-May-25	09-May-25
4: Analysis Completed Time				14:16	14:16	14:16
5: MAC	---	---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	06-May-25 08:13	10.8	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	06-May-25 08:26	10.8	---	0	0	---
8: TW TW-Whitechurch TW	06-May-25 08:15	10.8	1.48	0	0	< 10
9: DW DW-East Whitechurch DW-SS	06-May-25 07:57	10.8	1.05	0	0	10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster

Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

02-May-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 29 April 2025
LR Report: CA21639-APR25**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				30-Apr-25	30-Apr-25	30-Apr-25
2: Analysis Start Time				17:15	17:15	15:35
3: Analysis Completed Date				02-May-25	02-May-25	02-May-25
4: Analysis Completed Time				13:45	13:45	13:45
5: MAC	---	---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	29-Apr-25 08:01	9.7	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	29-Apr-25 08:16	9.7	---	0	0	---
8: TW TW-Whitechurch TW	29-Apr-25 07:58	9.7	1.51	0	0	< 10
9: DW DW-East Whitechurch DW-SS	29-Apr-25 07:49	9.7	1.15	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster

Project Specialist-London,
Environment, Health & Safety

25-April-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, CanadaDate Rec. : 22 April 2025
LR Report: **CA21164-APR25**

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS
Final Report**

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				23-Apr-25	23-Apr-25	23-Apr-25
2: Analysis Start Time				10:30	10:30	10:05
3: Analysis Completed Date				25-Apr-25	25-Apr-25	25-Apr-25
4: Analysis Completed Time				10:46	10:46	10:46
5: MAC	---	---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	22-Apr-25 08:55	12.3	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	22-Apr-25 08:48	12.3	---	0	0	---
8: TW TW-Whitechurch TW	22-Apr-25 09:09	12.3	1.70	0	0	< 10
9: DW DW-East Whitechurch DW-SS	22-Apr-25 08:21	12.3	1.53	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

23-April-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:


Date Rec. : 20 April 2025
LR Report: CA21031-APR25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				20-Apr-25	20-Apr-25	20-Apr-25
2: Analysis Start Time				16:30	16:30	16:20
3: Analysis Completed Date				22-Apr-25	22-Apr-25	22-Apr-25
4: Analysis Completed Time				18:26	18:26	18:26
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	20-Apr-25 05:07	7.6	1.21	0	0	< 10
7: DW DW-North Whitechurch DW-SS	20-Apr-25 04:49	7.6	1.34	0	0	< 10
8: DW DW-East Whitechurch DW-SS	20-Apr-25 04:42	7.6	1.40	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

17-April-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 14 April 2025
LR Report: CA20686-APR25

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				14-Apr-25	14-Apr-25	14-Apr-25
2: Analysis Start Time				16:40	16:40	16:10
3: Analysis Completed Date				16-Apr-25	16-Apr-25	16-Apr-25
4: Analysis Completed Time				17:53	17:53	17:53
5: MAC	---	---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	14-Apr-25 09:27	15.1	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	14-Apr-25 09:20	15.1	---	0	0	---
8: TW TW-Whitechurch TW	14-Apr-25 09:30	15.1	1.73	0	0	< 10
9: DW DW-East Whitechurch DW-SS	14-Apr-25 08:38	15.1	1.25	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster

Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

14-April-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 08 April 2025
LR Report: CA20535-APR25**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				09-Apr-25	09-Apr-25	09-Apr-25
2: Analysis Start Time				18:20	18:20	17:55
3: Analysis Completed Date				11-Apr-25	11-Apr-25	11-Apr-25
4: Analysis Completed Time				15:08	15:08	15:08
5: MAC	---	---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	08-Apr-25 08:38	5.1	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	08-Apr-25 08:29	5.1	---	0	0	---
8: TW TW-Whitechurch TW	08-Apr-25 08:27	5.1	1.55	0	0	< 10
9: DW DW-East Whitechurch DW-SS	08-Apr-25 08:15	5.1	1.42	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

04-April-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 01 April 2025
LR Report: CA20135-APR25

Copy: #1


CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	02-Apr-25	02-Apr-25	02-Apr-25
2: Analysis Start Time		---	---	10:45	10:45	10:10
3: Analysis Completed Date		---	---	04-Apr-25	04-Apr-25	04-Apr-25
4: Analysis Completed Time		---	---	10:51	10:51	10:51
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	01-Apr-25 11:04	6.9	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	01-Apr-25 11:09	6.9	---	0	0	---
8: TW TW-Whitechurch TW	01-Apr-25 11:12	6.9	1.63	0	0	< 10
9: DW DW-East Whitechurch DW-SS	01-Apr-25 10:39	6.9	1.43	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

31-March-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 25 March 2025
LR Report: CA21188-MAR25**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Mar-25	26-Mar-25	26-Mar-25
2: Analysis Start Time				16:55	16:55	16:25
3: Analysis Completed Date				28-Mar-25	28-Mar-25	28-Mar-25
4: Analysis Completed Time				18:13	18:13	18:13
5: MAC	---	---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	25-Mar-25 09:21	8.1	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	25-Mar-25 09:04	8.1	---	0	0	---
8: TW TW-Whitechurch TW	25-Mar-25 08:56	8.1	1.60	0	0	< 10
9: DW DW-East Whitechurch DW-SS	25-Mar-25 08:44	8.1	1.48	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

21-March-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:


Date Rec. : 18 March 2025
LR Report: CA20885-MAR25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				19-Mar-25	19-Mar-25	19-Mar-25
2: Analysis Start Time				15:55	15:55	15:15
3: Analysis Completed Date				21-Mar-25	21-Mar-25	21-Mar-25
4: Analysis Completed Time				14:16	14:16	14:16
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	18-Mar-25 08:05	11.9	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	18-Mar-25 08:13	11.9	---	0	0	---
8: TW TW-Whitechurch TW	18-Mar-25 08:11	11.9	1.62	0	0	< 10
9: DW DW-East Whitechurch DW-SS	18-Mar-25 07:55	11.9	1.57	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

14-March-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Date Rec. : 11 March 2025
LR Report: CA20510-MAR25

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				12-Mar-25	12-Mar-25	12-Mar-25
2: Analysis Start Time				13:55	13:55	13:30
3: Analysis Completed Date				14-Mar-25	14-Mar-25	14-Mar-25
4: Analysis Completed Time				12:52	12:52	12:52
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	11-Mar-25 13:11	8.3	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	11-Mar-25 13:17	8.3	---	0	0	---
8: TW TW-Whitechurch TW	11-Mar-25 13:27	8.3	1.78	0	0	< 10
9: DW DW-East Whitechurch DW-SS	11-Mar-25 12:52	8.3	1.45	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-March-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Date Rec. : 04 March 2025
LR Report: CA20180-MAR25

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Mar-25	05-Mar-25	05-Mar-25
2: Analysis Start Time				15:45	15:45	15:00
3: Analysis Completed Date				07-Mar-25	07-Mar-25	07-Mar-25
4: Analysis Completed Time				14:21	14:21	14:21
5: MAC	---	---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	04-Mar-25 08:12	8.6	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	04-Mar-25 08:24	8.6	---	0	0	---
8: TW TW-Whitechurch TW	04-Mar-25 08:15	8.6	1.70	0	0	< 10
9: DW DW-East Whitechurch DW-SS	04-Mar-25 08:00	8.6	1.63	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

28-February-2025

Date Rec. : 25 February 2025
LR Report: CA21180-FEB25

Copy: #1

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time		---	---	12:50	12:50	12:25
3: Analysis Completed Date		---	---	28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time		---	---	10:58	10:58	10:58
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	25-Feb-25 08:51	7.8	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	25-Feb-25 08:37	7.8	---	0	0	---
8: TW TW-Whitechurch TW	25-Feb-25 08:23	7.8	1.63	0	0	< 10
9: DW DW-East Whitechurch DW-SS	25-Feb-25 08:10	7.8	1.52	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

24-February-2025

Date Rec. : 19 February 2025
LR Report: CA21041-FEB25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				20-Feb-25	20-Feb-25	20-Feb-25
2: Analysis Start Time				14:45	14:45	14:10
3: Analysis Completed Date				24-Feb-25	24-Feb-25	24-Feb-25
4: Analysis Completed Time				10:50	10:50	10:50
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	19-Feb-25 08:46	10.8	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	19-Feb-25 08:54	10.8	---	0	0	---
8: TW TW-Whitechurch TW	19-Feb-25 09:01	10.8	1.76	0	0	< 10
9: DW DW-East Whitechurch DW-SS	19-Feb-25 08:37	10.8	1.68	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster

Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

14-February-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 11 February 2025
LR Report: CA20762-FEB25

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time				16:15	16:15	15:50
3: Analysis Completed Date				14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time				13:42	13:42	13:42
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	11-Feb-25 08:02	5.6	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	11-Feb-25 08:10	5.6	---	0	0	---
8: TW TW-Whitechurch TW	11-Feb-25 08:05	5.6	1.58	0	0	< 10
9: DW DW-East Whitechurch DW-SS	11-Feb-25 07:57	5.6	1.25	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:


Date Rec. : 04 February 2025
LR Report: CA20198-FEB25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time				14:00	14:00	13:20
3: Analysis Completed Date				07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time				14:25	14:25	14:25
5: MAC	---	---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	04-Feb-25 08:21	8.0	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	04-Feb-25 08:13	8.0	---	0	0	---
8: TW TW-Whitechurch TW	04-Feb-25 08:07	8.0	1.61	0	0	< 10
9: DW DW-East Whitechurch DW-SS	04-Feb-25 07:54	8.0	1.15	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

31-January-2025

Date Rec. : 28 January 2025
LR Report: CA21226-JAN25

Copy: #1

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				29-Jan-25	29-Jan-25	29-Jan-25
2: Analysis Start Time				16:00	16:00	15:35
3: Analysis Completed Date				31-Jan-25	31-Jan-25	31-Jan-25
4: Analysis Completed Time				13:07	13:07	13:07
5: MAC	---	---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	28-Jan-25 08:26	6.8	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	28-Jan-25 08:19	6.8	---	0	0	---
8: TW TW-Whitechurch TW	28-Jan-25 08:14	6.8	1.45	0	0	< 10
9: DW DW-East Whitechurch DW-SS	28-Jan-25 08:04	6.8	1.42	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

24-January-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 21 January 2025
LR Report: CA20941-JAN25

Copy: #1

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				22-Jan-25	22-Jan-25	22-Jan-25
2: Analysis Start Time				16:20	16:20	15:45
3: Analysis Completed Date				24-Jan-25	24-Jan-25	24-Jan-25
4: Analysis Completed Time				14:18	14:18	14:18
5: MAC	---	---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	21-Jan-25 09:12	4.9	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	21-Jan-25 09:20	4.9	---	0	0	---
8: TW TW-Whitechurch TW	21-Jan-25 09:15	4.9	1.51	0	0	< 10
9: DW DW-East Whitechurch DW-SS	21-Jan-25 08:13	4.9	1.33	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

17-January-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Date Rec. : 14 January 2025
LR Report: CA20583-JAN25

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:


CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				15-Jan-25	15-Jan-25	15-Jan-25
2: Analysis Start Time				15:00	15:00	14:35
3: Analysis Completed Date				17-Jan-25	17-Jan-25	17-Jan-25
4: Analysis Completed Time				12:42	12:42	12:42
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	14-Jan-25 10:33	6.0	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	14-Jan-25 10:17	6.0	---	0	0	---
8: TW TW-Whitechurch TW	14-Jan-25 10:13	6.0	1.54	0	0	< 10
9: DW DW-East Whitechurch DW-SS	14-Jan-25 09:57	6.0	1.34	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

13-January-2025

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Date Rec. : 08 January 2025
LR Report: CA20303-JAN25

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	08-Jan-25	08-Jan-25	08-Jan-25
2: Analysis Start Time		---	---	18:50	18:50	18:20
3: Analysis Completed Date		---	---	10-Jan-25	10-Jan-25	10-Jan-25
4: Analysis Completed Time		---	---	17:40	17:40	17:40
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	07-Jan-25 10:09	3.4	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	07-Jan-25 10:23	3.4	---	0	0	---
8: TW TW-Whitechurch TW	07-Jan-25 10:17	3.4	1.56	0	0	< 10
9: DW DW-East Whitechurch DW-SS	07-Jan-25 10:00	3.4	1.14	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety