

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

09-June-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 03 June 2025
 LR Report: CA20266-JUN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				04-Jun-25	04-Jun-25	04-Jun-25
2: Analysis Start Time				15:50	15:50	15:25
3: Analysis Completed Date				06-Jun-25	06-Jun-25	06-Jun-25
4: Analysis Completed Time				14:20	14:20	14:20
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	03-Jun-25 11:10	11.0	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	03-Jun-25 10:59	11.0	1.61	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	03-Jun-25 10:40	11.0	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	03-Jun-25 10:34	11.0	1.62	0	0	10
10: DW DW-86667 County Road 1 South (ACW)	03-Jun-25 11:36	11.0	1.42	0	0	10
11: DW DW-Lucknow Tower	03-Jun-25 11:25	11.0	1.35	0	0	< 10
12: DW DW-Lucknow SPS	03-Jun-25 11:50	11.0	1.60	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

30-May-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 27 May 2025
 LR Report: CA21538-MAY25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				28-May-25	28-May-25	28-May-25
2: Analysis Start Time				13:05	13:05	12:20
3: Analysis Completed Date				30-May-25	30-May-25	30-May-25
4: Analysis Completed Time				14:26	14:26	14:26
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	27-May-25 09:15	8.6	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	27-May-25 09:12	8.6	1.47	0	0	10
8: RW RW2-Lucknow RW-Well 5	27-May-25 08:58	8.6	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	27-May-25 09:02	8.6	1.77	0	0	10
10: DW DW-86667 County Road 1 South (ACW)	27-May-25 09:30	8.6	1.41	0	0	< 10
11: DW DW-Lucknow Tower	27-May-25 09:24	8.6	1.28	0	0	10
12: DW DW-Lucknow SPS	27-May-25 09:39	8.6	1.51	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

26-May-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 20 May 2025
 LR Report: CA21046-MAY25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				21-May-25	21-May-25	21-May-25
2: Analysis Start Time				13:30	13:30	13:05
3: Analysis Completed Date				23-May-25	23-May-25	23-May-25
4: Analysis Completed Time				16:10	16:10	16:10
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	20-May-25 10:19	12.7	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	20-May-25 10:16	12.7	1.59	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	20-May-25 09:42	12.7	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	20-May-25 09:36	12.7	1.65	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	20-May-25 10:56	12.7	1.41	0	0	< 10
11: DW DW-Lucknow Tower	20-May-25 10:42	12.7	1.30	0	0	< 10
12: DW DW-Lucknow SPS	20-May-25 11:11	12.7	1.51	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

26-May-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 20 May 2025
 LR Report: CA21046-MAY25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				21-May-25	21-May-25	21-May-25
2: Analysis Start Time				13:30	13:30	13:05
3: Analysis Completed Date				23-May-25	23-May-25	23-May-25
4: Analysis Completed Time				16:10	16:10	16:10
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	20-May-25 10:19	12.7	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	20-May-25 10:16	12.7	1.59	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	20-May-25 09:42	12.7	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	20-May-25 09:36	12.7	1.65	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	20-May-25 10:56	12.7	1.41	0	0	< 10
11: DW DW-Lucknow Tower	20-May-25 10:42	12.7	1.30	0	0	< 10
12: DW DW-Lucknow SPS	20-May-25 11:11	12.7	1.51	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

20-May-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 13 May 2025
 LR Report: CA20780-MAY25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	14-May-25	14-May-25	14-May-25
2: Analysis Start Time		---	---	16:10	16:10	15:50
3: Analysis Completed Date		---	---	16-May-25	16-May-25	16-May-25
4: Analysis Completed Time		---	---	15:54	15:54	15:54
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	13-May-25 09:42	11.9	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	13-May-25 09:40	11.9	1.65	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	13-May-25 09:24	11.9	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	13-May-25 09:19	11.9	1.72	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	13-May-25 10:00	11.9	1.43	0	0	< 10
11: DW DW-Lucknow Tower	13-May-25 09:53	11.9	1.42	0	0	< 10
12: DW DW-Lucknow SPS	13-May-25 10:07	11.9	1.51	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

09-May-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 06 May 2025
 LR Report: CA20328-MAY25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	07-May-25	07-May-25	07-May-25
2: Analysis Start Time		---	---	15:45	15:45	15:20
3: Analysis Completed Date		---	---	09-May-25	09-May-25	09-May-25
4: Analysis Completed Time		---	---	14:16	14:16	14:16
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	06-May-25 10:16	10.8	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	06-May-25 10:20	10.8	1.66	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	06-May-25 10:04	10.8	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	06-May-25 10:01	10.8	1.63	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	06-May-25 10:39	10.8	1.29	0	0	< 10
11: DW DW-Lucknow Tower	06-May-25 10:30	10.8	1.33	0	0	< 10
12: DW DW-Lucknow SPS	06-May-25 10:50	10.8	1.35	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

02-May-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 29 April 2025
 LR Report: CA21640-APR25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				30-Apr-25	30-Apr-25	30-Apr-25
2: Analysis Start Time				17:15	17:15	15:35
3: Analysis Completed Date				02-May-25	02-May-25	02-May-25
4: Analysis Completed Time				13:45	13:45	13:45
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	29-Apr-25 08:48	9.7	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	29-Apr-25 08:54	9.7	1.59	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	29-Apr-25 08:38	9.7	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	29-Apr-25 08:35	9.7	1.63	0	0	< 10
10: DW DW-86667 Country Road 1 South (ACW)	29-Apr-25 09:10	9.7	1.44	0	0	< 10
11: DW DW-Lucknow Tower	29-Apr-25 09:03	9.7	1.37	0	0	< 10
12: DW DW-Lucknow SPS	29-Apr-25 09:17	9.7	1.51	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

25-April-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 22 April 2025
 LR Report: CA21166-APR25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				23-Apr-25	23-Apr-25	23-Apr-25
2: Analysis Start Time				10:30	10:30	10:05
3: Analysis Completed Date				25-Apr-25	25-Apr-25	25-Apr-25
4: Analysis Completed Time				10:47	10:47	10:47
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	22-Apr-25 11:29	12.3	1.34	0	0	NDOGHPC
7: DW DW-Lucknow Tower	22-Apr-25 11:17	12.3	1.33	0	0	< 10
8: DW DW-Lucknow SPS	22-Apr-25 11:45	12.3	1.43	0	0	---
9: RW RW1-Lucknow RW-Well 4	22-Apr-25 10:31	12.3	---	0	0	---
10: TW TW1-Lucknow TW-Well 4	22-Apr-25 10:41	12.3	1.59	0	0	< 10
11: RW RW2-Lucknow RW-Well 5	22-Apr-25 10:04	12.3	---	0	0	---
12: TW TW2-Lucknow TW-Well 5	22-Apr-25 09:58	12.3	1.62	0	0	< 10

MAC - Maximum Acceptable Concentration
 NDOGHPC - No Data: Overgrown with HPC

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

17-April-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 14 April 2025
 LR Report: CA20687-APR25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				14-Apr-25	14-Apr-25	14-Apr-25
2: Analysis Start Time				16:40	16:40	16:10
3: Analysis Completed Date				16-Apr-25	16-Apr-25	16-Apr-25
4: Analysis Completed Time				17:53	17:53	17:53
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	14-Apr-25 10:35	15.1	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	14-Apr-25 10:24	15.1	1.73	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	14-Apr-25 11:38	15.1	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	14-Apr-25 11:36	15.1	1.80	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	14-Apr-25 11:13	15.1	1.46	0	0	< 10
11: DW DW-Lucknow Tower	14-Apr-25 10:55	15.1	1.49	0	0	< 10
12: DW DW-Lucknow SPS	14-Apr-25 11:24	15.1	1.55	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

14-April-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 08 April 2025
 LR Report: CA20534-APR25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				09-Apr-25	09-Apr-25	09-Apr-25
2: Analysis Start Time				18:20	18:20	17:55
3: Analysis Completed Date				11-Apr-25	11-Apr-25	11-Apr-25
4: Analysis Completed Time				15:08	15:08	15:08
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	08-Apr-25 09:17	5.1	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	08-Apr-25 09:15	5.1	1.72	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	08-Apr-25 09:03	5.1	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	08-Apr-25 09:01	5.1	1.75	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	08-Apr-25 09:36	5.1	1.56	0	0	< 10
11: DW DW-Lucknow Tower	08-Apr-25 09:30	5.1	1.45	0	0	< 10
12: DW DW-Lucknow SPS	08-Apr-25 09:47	5.1	1.43	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

04-April-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 01 April 2025
 LR Report: CA20133-APR25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	02-Apr-25	02-Apr-25	02-Apr-25
2: Analysis Start Time		---	---	10:45	10:45	10:10
3: Analysis Completed Date		---	---	04-Apr-25	04-Apr-25	04-Apr-25
4: Analysis Completed Time		---	---	10:50	10:50	10:50
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	01-Apr-25 08:19	6.9	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	01-Apr-25 08:13	6.9	1.70	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	01-Apr-25 09:05	6.9	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	01-Apr-25 09:00	6.9	1.85	0	0	10
10: DW DW-86667 County Road 1 South (ACW)	01-Apr-25 09:45	6.9	1.47	0	0	< 10
11: DW DW-Lucknow Tower	01-Apr-25 09:58	6.9	1.38	0	0	< 10
12: DW DW-Lucknow SPS	01-Apr-25 09:34	6.9	1.45	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

31-March-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 25 March 2025
 LR Report: CA21187-MAR25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Mar-25	26-Mar-25	26-Mar-25
2: Analysis Start Time				16:55	16:55	16:25
3: Analysis Completed Date				28-Mar-25	28-Mar-25	28-Mar-25
4: Analysis Completed Time				18:13	18:13	18:13
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	25-Mar-25 08:45	8.1	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	25-Mar-25 08:55	8.1	1.72	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	25-Mar-25 08:28	8.1	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	25-Mar-25 08:23	8.1	1.85	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	25-Mar-25 09:24	8.1	1.53	0	0	< 10
11: DW DW-Lucknow Tower	25-Mar-25 09:12	8.1	1.31	0	0	< 10
12: DW DW-Lucknow SPS	25-Mar-25 07:54	8.1	1.33	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

21-March-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 18 March 2025
 LR Report: CA20886-MAR25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				19-Mar-25	19-Mar-25	19-Mar-25
2: Analysis Start Time				15:55	15:55	15:15
3: Analysis Completed Date				21-Mar-25	21-Mar-25	21-Mar-25
4: Analysis Completed Time				14:17	14:17	14:17
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	18-Mar-25 10:19	11.9	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	18-Mar-25 10:25	11.9	1.51	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	18-Mar-25 10:11	11.9	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	18-Mar-25 10:09	11.9	1.71	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	18-Mar-25 08:43	11.9	1.30	0	0	< 10
11: DW DW-Lucknow Tower	18-Mar-25 10:36	11.9	1.40	0	0	10
12: DW DW-Lucknow SPS	18-Mar-25 09:55	11.9	1.35	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

14-March-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 11 March 2025
 LR Report: CA20511-MAR25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				12-Mar-25	12-Mar-25	12-Mar-25
2: Analysis Start Time				13:55	13:55	13:30
3: Analysis Completed Date				14-Mar-25	14-Mar-25	14-Mar-25
4: Analysis Completed Time				12:52	12:52	12:52
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	11-Mar-25 11:52	8.3	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	11-Mar-25 11:47	8.3	1.48	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	11-Mar-25 10:37	8.3	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	11-Mar-25 10:32	8.3	1.60	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	11-Mar-25 09:43	8.3	1.47	0	0	< 10
11: DW DW-Lucknow Tower	11-Mar-25 12:14	8.3	1.36	0	0	< 10
12: DW DW-Lucknow SPS	11-Mar-25 09:55	8.3	1.33	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

07-March-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 04 March 2025
 LR Report: CA20181-MAR25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Mar-25	05-Mar-25	05-Mar-25
2: Analysis Start Time				15:45	15:45	15:00
3: Analysis Completed Date				07-Mar-25	07-Mar-25	07-Mar-25
4: Analysis Completed Time				14:21	14:21	14:21
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	04-Mar-25 10:16	8.6	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	04-Mar-25 10:09	8.6	1.47	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	04-Mar-25 09:38	8.6	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	04-Mar-25 09:45	8.6	1.61	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	04-Mar-25 11:14	8.6	1.39	0	0	< 10
11: DW DW-Lucknow Tower	04-Mar-25 10:56	8.6	1.38	0	0	< 10
12: DW DW-Lucknow SPS	04-Mar-25 09:31	8.6	1.55	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 25 February 2025
 LR Report: CA21178-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time		---	---	12:50	12:50	12:25
3: Analysis Completed Date		---	---	28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time		---	---	10:52	10:52	10:52
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	25-Feb-25 09:30	7.8	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	25-Feb-25 09:35	7.8	1.58	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	25-Feb-25 09:21	7.8	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	25-Feb-25 09:16	7.8	1.80	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


 Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 25 February 2025
LR Report: CA21179-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time		---	---	12:50	12:50	12:25
3: Analysis Completed Date		---	---	28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time		---	---	10:58	10:58	10:58
5: MAC		---	---	0	0	---
6: DW DW-86667 Country Road 1 South (ACW)	25-Feb-25 09:51	7.8	1.50	0	0	< 10
7: DW DW-Lucknow Tower	25-Feb-25 09:43	7.8	1.45	0	0	< 10
8: DW DW-Lucknow SPS	25-Feb-25 09:59	7.8	1.59	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

24-February-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 19 February 2025
 LR Report: CA21040-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				20-Feb-25	20-Feb-25	20-Feb-25
2: Analysis Start Time				14:45	14:45	14:10
3: Analysis Completed Date				24-Feb-25	24-Feb-25	24-Feb-25
4: Analysis Completed Time				10:50	10:50	10:50
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	19-Feb-25 09:22	10.8	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	19-Feb-25 09:28	10.8	1.60	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	19-Feb-25 10:20	10.8	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	19-Feb-25 10:15	10.8	1.76	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	19-Feb-25 10:00	10.8	1.53	0	0	< 10
11: DW DW-Lucknow Tower	19-Feb-25 09:47	10.8	1.21	0	0	< 10
12: DW DW-Lucknow SPS	19-Feb-25 10:43	10.8	1.46	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

18-February-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 11 February 2025
 LR Report: CA20760-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time				17:10	17:10	16:45
3: Analysis Completed Date				14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time				16:19	16:19	16:19
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	11-Feb-25 11:05	5.6	1.39	0	0	< 10
7: DW DW-Lucknow Tower	11-Feb-25 10:12	5.6	1.37	0	0	< 10
8: DW DW-Lucknow SPS	11-Feb-25 10:56	5.6	1.44	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

18-February-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 11 February 2025
 LR Report: CA20761-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date			---	12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time			---	17:10	17:10	16:45
3: Analysis Completed Date			---	14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time			---	16:19	16:19	16:19
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	11-Feb-25 10:26	5.6	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	11-Feb-25 10:22	5.6	1.57	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	11-Feb-25 10:36	5.6	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	11-Feb-25 10:43	5.6	1.88	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 04 February 2025
LR Report: CA20196-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time				14:00	14:00	13:20
3: Analysis Completed Date				07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time				14:25	14:25	14:25
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	04-Feb-25 10:59	8.0	1.49	0	0	< 10
7: DW DW-Lucknow Tower	04-Feb-25 12:24	8.0	1.39	0	0	< 10
8: DW DW-Lucknow SPS	04-Feb-25 11:19	8.0	1.17	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 04 February 2025
LR Report: CA20197-FEB25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time				14:00	14:00	13:20
3: Analysis Completed Date				07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time				14:25	14:25	14:25
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	04-Feb-25 12:07	8.0	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	04-Feb-25 12:01	8.0	1.65	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	04-Feb-25 11:49	8.0	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	04-Feb-25 11:45	8.0	1.71	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

31-January-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 28 January 2025
 LR Report: CA21227-JAN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				29-Jan-25	29-Jan-25	29-Jan-25
2: Analysis Start Time				16:00	16:00	15:35
3: Analysis Completed Date				31-Jan-25	31-Jan-25	31-Jan-25
4: Analysis Completed Time				13:07	13:07	13:07
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	28-Jan-25 09:11	6.8	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	28-Jan-25 09:16	6.8	1.64	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	28-Jan-25 09:36	6.8	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	28-Jan-25 09:32	6.8	1.58	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	28-Jan-25 08:42	6.8	1.47	0	0	< 10
11: DW DW-Lucknow Tower	28-Jan-25 09:04	6.8	1.43	0	0	< 10
12: DW DW-Lucknow SPS	28-Jan-25 08:56	6.8	1.21	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

24-January-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 21 January 2025
 LR Report: CA20942-JAN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				22-Jan-25	22-Jan-25	22-Jan-25
2: Analysis Start Time				16:20	16:20	15:45
3: Analysis Completed Date				24-Jan-25	24-Jan-25	24-Jan-25
4: Analysis Completed Time				14:19	14:19	14:19
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	21-Jan-25 09:39	4.9	1.49	0	0	< 10
7: DW DW-Lucknow Tower	21-Jan-25 10:01	4.9	1.41	0	0	< 10
8: DW DW-Office	21-Jan-25 11:04	4.9	1.21	0	0	---
9: RW RW1-Lucknow RW-Well 4	21-Jan-25 10:06	4.9	---	0	0	---
10: TW TW1-Lucknow TW-Well 4	21-Jan-25 10:12	4.9	1.50	0	0	< 10
11: RW RW2-Lucknow RW-Well 5	21-Jan-25 10:35	4.9	---	0	0	---
12: TW TW2-Lucknow TW-Well 5	21-Jan-25 10:27	4.9	1.28	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

17-January-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 14 January 2025
LR Report: CA20582-JAN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				15-Jan-25	15-Jan-25	15-Jan-25
2: Analysis Start Time				15:00	15:00	14:35
3: Analysis Completed Date				17-Jan-25	17-Jan-25	17-Jan-25
4: Analysis Completed Time				12:42	12:42	12:42
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	14-Jan-25 09:38	6.0	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	14-Jan-25 09:29	6.0	1.50	0	0	10
8: RW RW2-Lucknow RW-Well 5	14-Jan-25 09:03	6.0	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	14-Jan-25 08:55	6.0	1.76	0	0	< 10
10: DW DW-86667 South (ACW)	14-Jan-25 08:43	6.0	1.47	0	0	10
11: DW DW-Lucknow SPS	14-Jan-25 08:33	6.0	1.51	0	0	< 10
12: DW DW-Old Firehall	14-Jan-25 08:10	6.0	1.62	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

13-January-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 08 January 2025
 LR Report: CA20304-JAN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	08-Jan-25	08-Jan-25	08-Jan-25
2: Analysis Start Time		---	---	18:50	18:50	18:20
3: Analysis Completed Date		---	---	10-Jan-25	10-Jan-25	10-Jan-25
4: Analysis Completed Time		---	---	17:41	17:41	17:41
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	07-Jan-25 09:35	3.4	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	07-Jan-25 09:30	3.4	1.48	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	07-Jan-25 08:30	3.4	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	07-Jan-25 08:24	3.4	1.75	0	0	< 10
10: DW DW-86667 South (ACW)	07-Jan-25 09:06	3.4	1.38	0	0	< 10
11: DW DW-Lucknow SPS	07-Jan-25 08:51	3.4	1.48	0	0	< 10
12: DW DW-Old Firehall	07-Jan-25 09:00	3.4	1.55	0	0	---
13: DW DW-Tower	07-Jan-25 09:20	3.4	1.42	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety