

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

09-June-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 03 June 2025  
 LR Report: CA20241-JUN25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				04-Jun-25	04-Jun-25	04-Jun-25
2: Analysis Start Time				09:40	09:40	09:30
3: Analysis Completed Date				06-Jun-25	06-Jun-25	06-Jun-25
4: Analysis Completed Time				11:10	11:10	11:10
5: MAC		---	---	0	0	---
6: TW TW1-Blairs Grove TW	03-Jun-25 08:48	11.0	1.44	0	0	< 10

MAC - Maximum Acceptable Concentration

#### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

09-June-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 03 June 2025  
 LR Report: CA20240-JUN25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				04-Jun-25	04-Jun-25	04-Jun-25
2: Analysis Start Time				09:40	09:40	09:30
3: Analysis Completed Date				06-Jun-25	06-Jun-25	06-Jun-25
4: Analysis Completed Time				11:10	11:10	11:10
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	02-Jun-25 13:52	11.0	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	02-Jun-25 14:17	11.0	---	0	0	---
8: TW TW3-Point Clark TW	02-Jun-25 14:12	11.0	1.35	0	0	< 10
9: DW DW-Point Clark Community Centre	02-Jun-25 14:35	11.0	1.50	0	0	< 10
10: RW RW2-Huronville South RW-Well 1	02-Jun-25 15:44	11.0	---	0	0	---
11: TW TW2-Huronville South TW	02-Jun-25 15:39	11.0	1.85	0	0	< 10
12: DW DW-Inverlyn Club House	02-Jun-25 15:58	11.0	1.74	0	0	< 10
13: RW RW5 Murdoch Glen RW-Well 2	02-Jun-25 15:13	11.0	---	0	0	---
14: TW TW4-Murdoch Glen TW	02-Jun-25 15:04	11.0	1.60	0	0	< 10
15: DW DW-Chem Shed	02-Jun-25 16:15	11.0	1.48	0	0	< 10
16: DW DW-Amberly Beach SS (ACW)	02-Jun-25 13:33	11.0	1.39	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20240-JUN25

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

30-May-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 27 May 2025  
 LR Report: CA21523-MAY25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				28-May-25	28-May-25	28-May-25
2: Analysis Start Time				09:35	09:35	09:15
3: Analysis Completed Date				30-May-25	30-May-25	30-May-25
4: Analysis Completed Time				12:02	12:02	12:02
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	26-May-25 14:59	6.4	---	0	0	---
7: TW TW2-Huronville South TW	26-May-25 14:56	6.4	1.75	0	0	< 10
8: DW DW-Inverlyn Club House	26-May-25 15:08	6.4	1.60	0	0	< 10
9: RW RW3-Point Clark RW-Well 2	26-May-25 13:40	6.4	---	0	0	---
10: RW RW4-Point Clark RW-Well 3	26-May-25 13:18	6.4	---	0	0	---
11: TW TW3-Point Clark TW	26-May-25 13:10	6.4	2.62	0	0	< 10
12: DW DW-Point Clark Community Centre	26-May-25 13:50	6.4	1.38	0	0	< 10
13: RW RW5-Murdoch Glen RW-Well 2	26-May-25 14:32	6.4	---	0	0	---
14: TW TW4-Murdoch Glen TW	26-May-25 14:30	6.4	1.48	0	0	< 10
15: DW DW-Chem Shed	26-May-25 14:00	6.4	1.44	0	0	< 10
16: DW DW-Amberly Beach SS (ACW)	26-May-25 12:50	6.4	1.44	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA21523-MAY25

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

23-May-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 20 May 2025  
 LR Report: CA21043-MAY25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				21-May-25	21-May-25	21-May-25
2: Analysis Start Time				11:00	11:00	10:30
3: Analysis Completed Date				23-May-25	23-May-25	23-May-25
4: Analysis Completed Time				11:27	11:27	11:27
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	20-May-25 09:58	12.7	---	0	0	---
7: TW TW2-Huronville South TW	20-May-25 10:03	12.7	1.76	0	0	< 10
8: DW DW-Inverlyn Club House	20-May-25 10:17	12.7	1.68	0	0	< 10
9: RW RW3-Point Clark RW-Well 2	20-May-25 08:27	12.7	---	0	0	---
10: RW RW4-Point Clark RW-Well 3	20-May-25 08:26	12.7	---	0	0	---
11: TW TW3-Point Clark TW	20-May-25 08:35	12.7	1.67	0	0	< 10
12: DW DW-Point Clark Community Centre	20-May-25 08:57	12.7	1.34	0	0	< 10
13: RW RW5-Murdoch Glen RW-Well 2	20-May-25 09:34	12.7	---	0	0	---
14: TW TW4-Murdoch Glen TW	20-May-25 09:32	12.7	1.48	0	0	< 10
15: DW DW-Chem Shed	20-May-25 09:07	12.7	1.56	0	0	< 10
16: DW DW-Amberly Beach SS (ACW)	20-May-25 08:18	12.7	1.54	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA21043-MAY25

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

16-May-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 13 May 2025  
 LR Report: CA20744-MAY25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	14-May-25	14-May-25	14-May-25
2: Analysis Start Time		---	---	10:00	10:00	09:35
3: Analysis Completed Date		---	---	16-May-25	16-May-25	16-May-25
4: Analysis Completed Time		---	---	10:44	10:44	10:44
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	12-May-25 15:13	11.9	---	0	0	---
7: TW TW2-Huronville South TW	12-May-25 15:15	11.9	1.80	0	0	< 10
8: DW DW-Inverlyn Club House	12-May-25 15:04	11.9	1.62	0	0	< 10
9: RW RW3-Point Clark RW-Well 2	12-May-25 12:43	11.9	---	0	0	---
10: RW RW4-Point Clark RW-Well 3	12-May-25 12:42	11.9	---	0	0	---
11: TW TW3-Point Clark TW	12-May-25 12:53	11.9	1.78	0	0	< 10
12: DW DW-Point Clark Community Centre	12-May-25 13:26	11.9	1.37	0	0	< 10
13: RW RW5-Murdoch Glen RW-Well 2	12-May-25 14:16	11.9	---	0	0	---
14: TW TW4-Murdoch Glen TW	12-May-25 14:12	11.9	1.60	0	0	< 10
15: DW DW-Chem Shed	12-May-25 13:33	11.9	1.56	0	0	< 10
16: DW DW-Amberley Beach SS (ACW)	12-May-25 12:33	11.9	1.38	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20744-MAY25

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

09-May-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 06 May 2025  
 LR Report: CA20298-MAY25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				07-May-25	07-May-25	07-May-25
2: Analysis Start Time				09:35	09:35	09:15
3: Analysis Completed Date				09-May-25	09-May-25	09-May-25
4: Analysis Completed Time				11:14	11:14	11:14
5: MAC		---	---	0	0	---
6: DW DW-Chem Shed	05-May-25 13:53	10.8	1.47	0	0	< 10
7: DW DW-Amberly Beach SS (ACW)	05-May-25 12:38	10.8	1.29	0	0	< 10
8: RW RW3-Point Clark RW-Well 2	05-May-25 13:25	10.8	---	0	0	---
9: RW RW4-Point Clark RW-Well 3	05-May-25 13:26	10.8	---	0	0	---
10: TW TW3-Point Clark TW	05-May-25 13:09	10.8	1.80	0	0	< 10
11: DW DW-Point Clark Community Centre	05-May-25 13:45	10.8	1.38	0	0	< 10
12: RW RW2-Huronville South RW-Well 1	05-May-25 15:18	10.8	---	0	0	---
13: TW TW2-Huronville South TW	05-May-25 15:14	10.8	1.75	0	0	10
14: DW DW-Inverlyn Club House	05-May-25 15:03	10.8	1.72	0	0	< 10
15: RW RW5-Murdoch Glen RW-Well 2	05-May-25 14:43	10.8	---	0	0	---
16: TW TW4-Murdoch Glen TW	05-May-25 14:34	10.8	1.34	0	0	< 10

MAC - Maximum Acceptable Concentration

#### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20298-MAY25

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

02-May-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 29 April 2025  
 LR Report: CA21613-APR25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	30-Apr-25	30-Apr-25	30-Apr-25
2: Analysis Start Time		---	---	09:35	09:35	09:10
3: Analysis Completed Date		---	---	02-May-25	02-May-25	02-May-25
4: Analysis Completed Time		---	---	09:41	09:41	09:41
5: MAC		---	---	0	0	---
6: DW DW-Chem Shed	28-Apr-25 13:31	9.7	1.50	0	0	< 10
7: DW DW-Amberley Beach SS (ACW)	28-Apr-25 12:33	9.7	1.18	0	0	< 10
8: RW RW3-Point Clark RW-Well 2	28-Apr-25 12:44	9.7	---	0	0	---
9: RW RW4-Point Clark RW-Well 3	28-Apr-25 13:10	9.7	---	0	0	---
10: TW TW3-Point Clark TW	28-Apr-25 12:53	9.7	1.79	0	0	< 10
11: DW DW-Point Clark Community Centre	28-Apr-25 13:22	9.7	1.48	0	0	< 10
12: RW RW5-Murdoch Glen RW-Well 2	28-Apr-25 14:03	9.7	---	0	0	---
13: TW TW4-Murdoch Glen TW	28-Apr-25 14:02	9.7	1.34	0	0	< 10
14: RW RW2-Huronville South RW-Well 1	28-Apr-25 14:19	9.7	---	0	0	---
15: TW TW2-Huronville South TW	28-Apr-25 14:24	9.7	1.84	0	0	< 10
16: DW DW-Inverlyn Club House	28-Apr-25 14:35	9.7	1.47	0	0	< 10

MAC - Maximum Acceptable Concentration

#### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

\_\_\_\_\_  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA21613-APR25

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

25-April-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 22 April 2025  
 LR Report: CA21167-APR25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				23-Apr-25	23-Apr-25	23-Apr-25
2: Analysis Start Time				10:30	10:30	10:05
3: Analysis Completed Date				25-Apr-25	25-Apr-25	25-Apr-25
4: Analysis Completed Time				10:47	10:47	10:47
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well 2	22-Apr-25 10:46	12.3	---	0	0	---
7: TW TW4-Murdoch Glen TW	22-Apr-25 10:43	12.3	1.60	0	0	< 10
8: RW RW2-Huronville South RW-Well 1	22-Apr-25 11:03	12.3	---	0	0	---
9: TW TW2-Huronville South TW	22-Apr-25 11:10	12.3	1.55	0	0	< 10
10: DW DW-Inverlyn Club House	22-Apr-25 11:20	12.3	1.43	0	0	< 10
11: RW RW3-Point Clark RW-Well 2	22-Apr-25 09:50	12.3	---	0	0	---
12: RW RW4-Point Clark RW-Well 3	22-Apr-25 09:52	12.3	---	0	0	---
13: TW TW3-Point Clark TW	22-Apr-25 09:09	12.3	1.80	0	0	< 10
14: DW DW-Point Clark Community Centre	22-Apr-25 10:05	12.3	1.34	0	0	< 10
15: DW DW-Chem Shed	22-Apr-25 10:14	12.3	1.39	0	0	< 10
16: DW DW-Amberly Beach SS (ACW)	22-Apr-25 08:45	12.3	1.20	0	0	< 10

MAC - Maximum Acceptable Concentration

#### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA21167-APR25

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

17-April-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 14 April 2025  
 LR Report: CA20689-APR25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				14-Apr-25	14-Apr-25	14-Apr-25
2: Analysis Start Time				16:40	16:40	16:10
3: Analysis Completed Date				16-Apr-25	16-Apr-25	16-Apr-25
4: Analysis Completed Time				17:53	17:53	17:53
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	14-Apr-25 11:20	10.0	---	0	0	---
7: TW TW2-Huronville South TW	14-Apr-25 11:28	10.0	1.53	0	0	10
8: DW DW-Inverlyn Club House	14-Apr-25 11:08	10.0	1.25	0	0	< 10
9: DW DW-Chem Shed	14-Apr-25 09:27	10.0	1.51	0	0	< 10
10: DW DW-Amberly Beach SS (ACW)	14-Apr-25 08:39	10.0	1.42	0	0	< 10
11: RW RW3-Point Clark RW-Well 2	14-Apr-15 08:49	10.0	---	0	0	---
12: RW RW4-Point Clark RW-Well 3	14-Apr-15 08:54	10.0	---	0	0	---
13: TW TW3-Point Clark TW	14-Apr-15 08:55	10.0	1.81	0	0	< 10
14: DW DW-Point Clark Community Centre	14-Apr-15 09:16	10.0	1.41	0	0	< 10
15: RW RW5-Murdoch Glen RW-Well 2	14-Apr-25 10:29	10.0	---	0	0	---
16: TW TW4-Murdoch Glen TW	14-Apr-25 10:23	10.0	2.30	0	0	< 10

MAC - Maximum Acceptable Concentration

#### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20689-APR25

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

11-April-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 08 April 2025  
 LR Report: CA20502-APR25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				09-Apr-25	09-Apr-25	09-Apr-25
2: Analysis Start Time				10:15	10:15	09:50
3: Analysis Completed Date				11-Apr-25	11-Apr-25	11-Apr-25
4: Analysis Completed Time				10:34	10:34	10:34
5: MAC		---	---	0	0	---
6: DW DW-Chem Shed	07-Apr-25 13:41	5.1	1.63	0	0	< 10
7: DW DW-Amberly Beach SS (ACW)	07-Apr-25 12:49	5.1	1.54	0	0	< 10
8: RW RW3-Point Clark RW-Well 2	07-Apr-25 13:01	5.1	---	0	0	---
9: RW RW4-Point Clark RW-Well 3	07-Apr-25 13:17	5.1	---	0	0	---
10: TW TW3-Point Clark TW	07-Apr-25 13:14	5.1	1.92	0	0	< 10
11: DW DW-Point Clark Community Centre	07-Apr-25 13:33	5.1	1.45	0	0	< 10
12: RW RW5-Murdoch Glen RW-Well 2	07-Apr-25 13:23	5.1	---	0	0	---
13: TW TW4-Murdoch Glen TW	07-Apr-25 13:19	5.1	2.11	0	0	< 10
14: RW RW2-Huronville South RW-Well 1	07-Apr-25 13:51	5.1	---	0	0	---
15: TW TW2-Huronville South TW	07-Apr-25 14:17	5.1	1.51	0	0	< 10
16: DW DW-Inverlyn Club House	07-Apr-25 14:41	5.1	1.56	0	0	< 10

MAC - Maximum Acceptable Concentration

#### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20502-APR25

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

04-April-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 01 April 2025  
 LR Report: CA20132-APR25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	02-Apr-25	02-Apr-25	02-Apr-25
2: Analysis Start Time		---	---	10:45	10:45	10:10
3: Analysis Completed Date		---	---	04-Apr-25	04-Apr-25	04-Apr-25
4: Analysis Completed Time		---	---	10:50	10:50	10:50
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	31-Mar-25 14:09	6.9	---	0	0	---
7: TW TW2-Huronville South TW	31-Mar-25 14:11	6.9	1.55	0	0	< 10
8: DW DW-Inverlyn Club House	31-Mar-25 14:28	6.9	1.29	0	0	< 10
9: RW RW3-Point Clark RW-Well 2	31-Mar-25 13:49	6.9	---	0	0	---
10: RW RW4-Point Clark RW-Well 3	31-Mar-25 13:50	6.9	---	0	0	---
11: TW TW3-Point Clark TW	31-Mar-25 13:19	6.9	1.80	0	0	< 10
12: DW DW-Point Clark Community Centre	31-Mar-25 14:04	6.9	1.53	0	0	< 10
13: RW RW5-Murdoch Glen RW-Well 2	31-Mar-25 13:14	6.9	---	0	0	---
14: TW TW4-Murdoch Glen TW	31-Mar-25 13:12	6.9	2.40	0	0	< 10
15: DW DW-Chem Shed	31-Mar-25 14:13	6.9	1.58	0	0	< 10
16: DW DW-Amberly Beach SS (ACW)	31-Mar-25 12:48	6.9	1.60	0	0	< 10

MAC - Maximum Acceptable Concentration

#### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20132-APR25

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

28-March-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 25 March 2025  
 LR Report: CA21180-MAR25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Mar-25	26-Mar-25	26-Mar-25
2: Analysis Start Time				10:00	10:00	09:45
3: Analysis Completed Date				28-Mar-25	28-Mar-25	28-Mar-25
4: Analysis Completed Time				11:10	11:10	11:10
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	24-Mar-25 13:16	8.1	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	24-Mar-25 13:18	8.1	---	0	0	---
8: TW TW3-Point Clark TW	24-Mar-25 13:25	8.1	1.97	0	0	< 10
9: DW DW-Point Clark Community Centre	24-Mar-25 13:43	8.1	1.53	0	0	< 10
10: DW DW-Chem Shed	24-Mar-25 14:01	8.1	1.51	0	0	< 10
11: DW DW-Amberly Beach SS (ACW)	24-Mar-25 14:24	8.1	1.64	0	0	< 10
12: RW RW5-Murdoch Glen RW-Well 2	24-Mar-25 14:59	8.1	---	0	0	---
13: TW TW4-Murdoch Glen TW	24-Mar-25 14:54	8.1	2.48	0	0	< 10
14: RW RW2-Huronville South RW-Well 1	24-Mar-25 15:09	8.1	---	0	0	---
15: TW TW2-Huronville South TW	24-Mar-25 15:19	8.1	1.59	0	0	< 10
16: DW DW-Inverlyn Club House	24-Mar-25 15:27	8.1	1.60	0	0	< 10

MAC - Maximum Acceptable Concentration

#### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA21180-MAR25

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

21-March-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 18 March 2025  
 LR Report: CA20881-MAR25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				19-Mar-25	19-Mar-25	19-Mar-25
2: Analysis Start Time				09:35	09:35	09:10
3: Analysis Completed Date				21-Mar-25	21-Mar-25	21-Mar-25
4: Analysis Completed Time				10:08	10:08	10:08
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well 2	17-Mar-25 14:37	11.9	---	0	0	---
7: TW TW4-Murdoch Glen TW	17-Mar-25 14:32	11.9	2.54	0	0	< 10
8: DW DW-Chem Shed	17-Mar-25 13:54	11.9	1.58	0	0	< 10
9: DW DW-Amberly Beach SS (ACW)	17-Mar-25 13:02	11.9	1.56	0	0	< 10
10: RW RW3-Point Clark RW-Well 2	17-Mar-25 13:16	11.9	---	0	0	---
11: RW RW4-Point Clark RW-Well 3	17-Mar-25 13:29	11.9	---	0	0	---
12: TW TW3-Point Clark TW	17-Mar-25 13:23	11.9	1.94	0	0	< 10
13: DW DW-Point Clark Community Centre	17-Mar-25 13:45	11.9	1.62	0	0	< 10
14: RW RW2-Huronville South RW-Well 1	17-Mar-25 14:53	11.9	---	0	0	---
15: TW TW2-Huronville South TW	17-Mar-25 15:00	11.9	1.54	0	0	< 10
16: DW DW-Inverlyn Club House	17-Mar-25 15:09	11.9	1.28	0	0	< 10

MAC - Maximum Acceptable Concentration

#### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20881-MAR25

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

14-March-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 11 March 2025  
 LR Report: CA20507-MAR25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				12-Mar-25	12-Mar-25	12-Mar-25
2: Analysis Start Time				11:00	11:00	10:30
3: Analysis Completed Date				14-Mar-25	14-Mar-25	14-Mar-25
4: Analysis Completed Time				11:47	11:47	11:47
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	10-Mar-25 14:08	8.3	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	10-Mar-25 14:01	8.3	---	0	0	---
8: TW TW3-Point Clark TW	10-Mar-25 13:11	8.3	1.94	0	0	< 10
9: DW DW-Point Clark Community Centre	10-Mar-25 13:21	8.3	1.52	0	0	< 10
10: RW RW2-Huronville South RW-Well 1	10-Mar-25 14:25	8.3	---	0	0	---
11: TW TW2-Huronville South TW	10-Mar-25 14:26	8.3	1.46	0	0	< 10
12: DW DW-Inverlyn Club House	10-Mar-25 14:36	8.3	1.26	0	0	< 10
13: RW RW5-Murdoch Glen RW-Well 2	10-Mar-25 14:10	8.3	---	0	0	---
14: TW TW4-Murdoch Glen TW	10-Mar-25 14:04	8.3	2.48	0	0	< 10
15: DW DW-Chem Shed	10-Mar-25 13:55	8.3	1.64	0	0	< 10
16: DW DW-Amberly Store	10-Mar-25 12:50	8.3	1.32	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20507-MAR25

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

07-March-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 04 March 2025  
 LR Report: CA20174-MAR25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

# CERTIFICATE OF ANALYSIS


## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Mar-25	05-Mar-25	05-Mar-25
2: Analysis Start Time				10:25	10:25	09:35
3: Analysis Completed Date				07-Mar-25	07-Mar-25	07-Mar-25
4: Analysis Completed Time				09:53	09:53	09:53
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	03-Mar-25 12:39	8.6	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	03-Mar-25 12:55	8.6	---	0	0	---
8: TW TW3-Point Clark TW	03-Mar-25 12:46	8.6	1.57	0	0	< 10
9: DW DW-Point Clark Community Centre	03-Mar-25 12:49	8.6	1.68	0	0	< 10
10: RW RW5-Murdoch Glen RW-Well 2	03-Mar-25 13:26	8.6	---	0	0	---
11: TW TW4-Murdoch Glen TW	03-Mar-25 13:21	8.6	2.40	0	0	< 10
12: RW RW2-Huronville South RW-Well 1	03-Mar-25 13:53	8.6	---	0	0	---
13: TW TW2-Huronville South TW	03-Mar-25 13:46	8.6	1.45	0	0	< 10
14: DW DW-Inverlyn Club House	03-Mar-25 13:16	8.6	1.66	0	0	< 10
15: DW DW-Chem Shed	03-Mar-25 13:00	8.6	1.64	0	0	< 10
16: DW DW-Amberly Store (ACW)	03-Mar-25 12:35	8.6	1.42	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20174-MAR25

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

**Date Rec. :** 25 February 2025  
**LR Report:** CA21160-FEB25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time				09:55	09:55	09:20
3: Analysis Completed Date				28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time				10:41	10:41	10:41
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well 2	24-Feb-25 13:34	7.8	---	0	0	---
7: TW TW4-Murdoch Glen TW	24-Feb-25 13:31	7.8	2.52	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 25 February 2025  
 LR Report: CA21161-FEB25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time				09:55	09:55	09:20
3: Analysis Completed Date				28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time				10:41	10:41	10:41
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	24-Feb-25 13:47	7.8	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	24-Feb-25 13:49	7.8	---	0	0	---
8: TW TW3-Point Clark TW	24-Feb-25 13:30	7.8	1.65	0	0	< 10
9: DW DW-Point Clark Community Centre	24-Feb-25 14:14	7.8	1.37	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

**Date Rec. :** 25 February 2025  
**LR Report:** CA21162-FEB25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time				09:55	09:55	09:20
3: Analysis Completed Date				28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time				10:41	10:41	10:41
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	24-Feb-25 14:08	7.8	---	0	0	---
7: TW TW2-Huronville South TW	24-Feb-25 14:05	7.8	1.53	0	0	< 10
8: DW DW-Inverlyn Club House	24-Feb-25 14:22	7.8	1.35	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
 \_\_\_\_\_  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 25 February 2025  
 LR Report: CA21163-FEB25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time				09:55	09:55	09:20
3: Analysis Completed Date				28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time				10:41	10:41	10:41
5: MAC		---	---	0	0	---
6: DW DW-Chem Shed	24-Feb-25 14:25	7.8	1.41	0	0	< 10
7: DW DW-Amberly Store (ACW)	24-Feb-25 13:05	7.8	1.61	0	0	< 10

MAC - Maximum Acceptable Concentration

#### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

24-February-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

**Date Rec. :** 19 February 2025  
**LR Report:** CA21029-FEB25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	20-Feb-25	20-Feb-25	20-Feb-25
2: Analysis Start Time		---	---	12:55	12:55	12:25
3: Analysis Completed Date		---	---	24-Feb-25	24-Feb-25	24-Feb-25
4: Analysis Completed Time		---	---	10:15	10:15	10:15
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	19-Feb-25 09:23	10.8	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	19-Feb-25 09:01	10.8	---	0	0	---
8: TW TW3-Point Clark TW	19-Feb-25 09:04	10.8	1.02	0	0	< 10
9: DW DW-Point Clark Community Centre	19-Feb-25 09:38	10.8	1.77	0	0	< 10
10: RW RW2-Huronville South RW-Well 1	19-Feb-25 10:35	10.8	---	0	0	---
11: TW TW2-Huronville South TW	19-Feb-25 10:31	10.8	1.53	0	0	< 10
12: DW DW-Inverlyn Club House	19-Feb-25 10:49	10.8	1.24	0	0	< 10
13: RW RW5-Murdoch Glen RW-Well 2	19-Feb-25 10:15	10.8	---	0	0	---
14: TW TW4-Murdoch Glen TW	19-Feb-25 10:10	10.8	2.40	0	0	< 10
15: DW DW-Chem Shed	19-Feb-25 09:49	10.8	1.81	0	0	< 10
16: DW DW-Amberly Store (ACW)	19-Feb-25 08:45	10.8	1.82	0	0	< 10

MAC - Maximum Acceptable Concentration

#### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA21029-FEB25

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

14-February-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 11 February 2025  
 LR Report: CA20724-FEB25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time		---	---	09:20	09:20	09:05
3: Analysis Completed Date		---	---	14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time		---	---	10:45	10:45	10:45
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	10-Feb-25 14:12	5.6	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	10-Feb-25 14:14	5.6	---	0	0	---
8: TW TW3-Point Clark TW	10-Feb-25 13:55	5.6	2.64	0	0	< 10
9: DW DW-Point Clark Community Centre	10-Feb-25 14:29	5.6	1.61	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

14-February-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

**Date Rec. :** 11 February 2025  
**LR Report:** CA20725-FEB25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS


### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time		---	---	09:20	09:20	09:05
3: Analysis Completed Date		---	---	14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time		---	---	10:46	10:46	10:46
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW - Well 3	10-Feb-25 15:06	5.6	---	0	0	---
7: TW TW1-Blairs Grove TW	10-Feb-25 14:59	5.6	2.42	0	0	10
8: DW DW-Chem Shed	10-Feb-25 15:16	5.6	2.03	0	0	< 10
9: DW DW-Elliots Construction	10-Feb-25 13:35	5.6	1.80	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

14-February-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 11 February 2025  
 LR Report: CA20726-FEB25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time		---	---	09:20	09:20	09:05
3: Analysis Completed Date		---	---	14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time		---	---	10:46	10:46	10:46
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	10-Feb-25 16:11	5.6	---	0	0	---
7: TW TW2-Huronville South TW	10-Feb-25 16:08	5.6	1.61	0	0	< 10
8: DW DW-Inverlyn Club House	10-Feb-25 16:19	5.6	1.21	0	0	< 10

MAC - Maximum Acceptable Concentration

#### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
 \_\_\_\_\_  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

14-February-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 11 February 2025  
 LR Report: CA20727-FEB25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time		---	---	09:20	09:20	09:05
3: Analysis Completed Date		---	---	14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time		---	---	10:46	10:46	10:46
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well 2	10-Feb-25 15:44	5.6	---	0	0	---
7: TW TW4-Murdoch Glen TW	10-Feb-25 15:34	5.6	2.50	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 04 February 2025  
 LR Report: CA20189-FEB25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time		---	---	10:00	10:00	09:50
3: Analysis Completed Date		---	---	07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time		---	---	09:59	09:59	09:59
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW - Well 3	03-Feb-25 13:47	8.0	---	0	0	---
7: TW TW1-Blairs Grove TW	03-Feb-25 13:44	8.0	1.62	0	0	< 10
8: DW DW-Chem Shed	03-Feb-25 13:28	8.0	1.44	0	0	< 10
9: DW DW-Courtney Subdivision	03-Feb-25 12:30	8.0	1.45	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.  
 Branch Manager-London  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

**Date Rec. :** 04 February 2025  
**LR Report:** CA20190-FEB25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time		---	---	10:00	10:00	09:50
3: Analysis Completed Date		---	---	07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time		---	---	09:59	09:59	09:59
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	03-Feb-25 12:44	8.0	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	03-Feb-25 12:46	8.0	---	0	0	---
8: TW TW3-Point Clark TW	03-Feb-25 12:56	8.0	2.32	0	0	< 10
9: DW DW-Point Clark Community Centre	03-Feb-25 13:14	8.0	1.47	0	0	10

MAC - Maximum Acceptable Concentration

#### Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Angela Stott, B.Sc.**  
 Branch Manager-London  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

**Date Rec. :** 04 February 2025  
**LR Report:** CA20191-FEB25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time		---	---	10:00	10:00	09:50
3: Analysis Completed Date		---	---	07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time		---	---	09:59	09:59	09:59
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	03-Feb-25 17:36	8.0	---	0	0	---
7: TW TW2-Huronville South TW	03-Feb-25 17:45	8.0	1.55	0	0	< 10
8: DW DW-Inverlyn Club House	03-Feb-25 18:09	8.0	1.30	0	0	< 10

MAC - Maximum Acceptable Concentration

#### Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Angela Stott, B.Sc.**  
 Branch Manager-London  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

**Date Rec. :** 04 February 2025  
**LR Report:** CA20192-FEB25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time		---	---	10:00	10:00	09:50
3: Analysis Completed Date		---	---	07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time		---	---	09:59	09:59	09:59
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well 2	03-Feb-25 14:49	8.0	---	0	0	---
7: TW TW4-Murdoch Glen TW	03-Feb-25 14:41	8.0	2.54	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Angela Stott, B.Sc.**  
 Branch Manager-London  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

31-January-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 28 January 2025  
 LR Report: CA21186-JAN25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	29-Jan-25	29-Jan-25	29-Jan-25
2: Analysis Start Time		---	---	09:40	09:40	09:30
3: Analysis Completed Date		---	---	31-Jan-25	31-Jan-25	31-Jan-25
4: Analysis Completed Time		---	---	09:47	09:47	09:47
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	27-Jan-25 14:50	6.8	---	0	0	---
7: TW TW2-Huronville South TW	27-Jan-25 14:53	6.8	1.52	0	0	< 10
8: DW DW-Inverlyn Club House	27-Jan-25 15:05	6.8	1.42	0	0	< 10
9: RW RW1-Blairs Grove RW - Well 3	27-Jan-25 14:06	6.8	---	0	0	---
10: TW TW1-Blairs Grove TW	27-Jan-25 14:12	6.8	1.61	0	0	< 10
11: DW DW-Chem Shed	27-Jan-25 13:56	6.8	1.45	0	0	< 10
12: DW DW-Elliots Construction	27-Jan-25 13:10	6.8	1.39	0	0	< 10
13: RW RW3-Point Clark RW-Well 2	27-Jan-25 13:32	6.8	---	0	0	---
14: RW RW4-Point Clark RW-Well 3	27-Jan-25 13:30	6.8	---	0	0	---
15: TW TW3-Point Clark TW	27-Jan-25 13:28	6.8	1.46	0	0	< 10
16: DW DW-Point Clark Community Centre	27-Jan-25 13:45	6.8	1.49	0	0	< 10
17: RW RW5-Murdoch Glen RW-Well	27-Jan-25 14:35	6.8	---	0	0	---
18: TW TW4-Murdoch Glen TW	27-Jan-25 14:32	6.8	2.34	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

**Cristal Schuster**  
 Project Specialist-London,

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

24-January-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 21 January 2025  
 LR Report: CA20911-JAN25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	22-Jan-25	22-Jan-25	22-Jan-25
2: Analysis Start Time		---	---	10:30	10:30	09:50
3: Analysis Completed Date		---	---	24-Jan-25	24-Jan-25	24-Jan-25
4: Analysis Completed Time		---	---	10:39	10:39	10:39
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	20-Jan-25 13:37	4.9	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	20-Jan-25 14:04	4.9	---	0	0	---
8: TW TW3-Point Clark TW	20-Jan-25 13:31	4.9	1.55	0	0	< 10
9: DW DW-Point Clark Community Centre	20-Jan-25 14:37	4.9	1.45	0	0	< 10

MAC - Maximum Acceptable Concentration

#### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA21186-JAN25

*Environment, Health & Safety*

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

24-January-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

**Date Rec. :** 21 January 2025  
**LR Report:** CA20912-JAN25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	22-Jan-25	22-Jan-25	22-Jan-25
2: Analysis Start Time		---	---	10:30	10:30	09:50
3: Analysis Completed Date		---	---	24-Jan-25	24-Jan-25	24-Jan-25
4: Analysis Completed Time		---	---	10:40	10:40	10:40
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well	20-Jan-25 16:29	4.9	---	0	0	---
7: TW TW4-Murdoch Glen TW	20-Jan-25 16:22	4.9	2.20	0	0	< 10

MAC - Maximum Acceptable Concentration

#### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

24-January-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

**Date Rec. :** 21 January 2025  
**LR Report:** CA20913-JAN25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

**Copy:** #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	22-Jan-25	22-Jan-25	22-Jan-25
2: Analysis Start Time		---	---	10:30	10:30	09:50
3: Analysis Completed Date		---	---	24-Jan-25	24-Jan-25	24-Jan-25
4: Analysis Completed Time		---	---	10:40	10:40	10:40
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW-Well 3	20-Jan-25 17:04	4.9	---	0	0	---
7: TW TW1-Blairs Grove TW	20-Jan-25 17:02	4.9	1.63	0	0	< 10
8: DW DW-Chem Shed	20-Jan-25 11:53	4.9	1.46	0	0	< 10
9: DW DW-Elliots Construction	20-Jan-25 13:20	4.9	1.51	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

24-January-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 21 January 2025  
 LR Report: CA20914-JAN25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	22-Jan-25	22-Jan-25	22-Jan-25
2: Analysis Start Time		---	---	10:30	10:30	09:50
3: Analysis Completed Date		---	---	24-Jan-25	24-Jan-25	24-Jan-25
4: Analysis Completed Time		---	---	10:42	10:42	10:42
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	20-Jan-25 16:40	4.9	---	0	0	---
7: TW TW2-Huronville South TW	20-Jan-25 16:36	4.9	1.50	0	0	< 10
8: DW DW-Inverlyn Club House	20-Jan-25 16:51	4.9	1.43	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
 \_\_\_\_\_  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

21-January-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 14 January 2025  
 LR Report: CA20566-JAN25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS


### Draft Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	15-Jan-25	15-Jan-25	15-Jan-25
2: Analysis Start Time		---	---	09:10	09:10	09:00
3: Analysis Completed Date		---	---	17-Jan-25	17-Jan-25	17-Jan-25
4: Analysis Completed Time		---	---	10:29	10:29	10:29
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	13-Jan-25 16:10	6.0	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	13-Jan-25 16:05	6.0	---	0	0	---
8: TW TW3-Point Clark TW	13-Jan-25 16:02	6.0	1.40	0	0	< 10
9: DW DW-Point Clark Community Centre	13-Jan-25 15:22	6.0	1.45	0	0	10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

17-January-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 14 January 2025  
 LR Report: CA20563-JAN25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	15-Jan-25	15-Jan-25	15-Jan-25
2: Analysis Start Time		---	---	09:10	09:10	09:00
3: Analysis Completed Date		---	---	17-Jan-25	17-Jan-25	17-Jan-25
4: Analysis Completed Time		---	---	10:28	10:28	10:28
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW - Well 3	13-Jan-25 15:10	6.0	---	0	0	---
7: TW TW1-Blairs Grove TW	13-Jan-25 15:07	6.0	1.61	0	0	< 10
8: DW DW-Chem Shed	13-Jan-25 14:46	6.0	1.38	0	0	< 10
9: DW DW-Elliots Construction	13-Jan-25 15:48	6.0	1.30	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

17-January-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 14 January 2025  
 LR Report: CA20564-JAN25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	15-Jan-25	15-Jan-25	15-Jan-25
2: Analysis Start Time		---	---	09:10	09:10	09:00
3: Analysis Completed Date		---	---	17-Jan-25	17-Jan-25	17-Jan-25
4: Analysis Completed Time		---	---	10:29	10:29	10:29
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well	13-Jan-25 14:26	6.0	---	0	0	---
7: TW TW4-Murdoch Glen TW	13-Jan-25 14:13	6.0	1.55	0	0	< 10

MAC - Maximum Acceptable Concentration

#### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

17-January-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 14 January 2025  
 LR Report: CA20565-JAN25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	15-Jan-25	15-Jan-25	15-Jan-25
2: Analysis Start Time		---	---	09:10	09:10	09:00
3: Analysis Completed Date		---	---	17-Jan-25	17-Jan-25	17-Jan-25
4: Analysis Completed Time		---	---	10:29	10:29	10:29
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	13-Jan-25 13:58	6.0	---	0	0	---
7: TW TW2-Huronville South TW	13-Jan-25 13:53	6.0	1.57	0	0	< 10
8: DW DW-Inverlyn Club House	13-Jan-25 13:43	6.0	1.29	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
 \_\_\_\_\_  
**Cristal Schuster**  
 Project Specialist-London,  
 Environment, Health & Safety

**SGS Canada Inc.**  
 657 Consortium Court  
 London - Ontario - N6E 2S8  
 Phone: 519-672-4500 FAX: 519-672-0361

13-January-2025

**OCWA-Huron Kinloss (Lakeshore DWS)**

Attn : Paul Sherban

Date Rec. : 08 January 2025  
 LR Report: CA20301-JAN25

6242 Fallon Drive  
 Lucan, ON  
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)  
 Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	08-Jan-25	08-Jan-25	08-Jan-25
2: Analysis Start Time		---	---	12:45	12:45	12:05
3: Analysis Completed Date		---	---	10-Jan-25	10-Jan-25	10-Jan-25
4: Analysis Completed Time		---	---	11:12	11:12	11:12
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW-Well 3	06-Jan-25 15:00	8.8	---	0	0	---
7: TW TW1-Blairs Grove TW	06-Jan-25 14:56	8.8	1.61	0	0	< 10
8: DW DW-Chem Shed	06-Jan-25 14:41	8.8	1.18	0	0	< 10
9: DW DW-Elliots Construction (ACW)	06-Jan-25 13:50	8.8	1.47	0	0	30
10: RW RW3-Point Clark RW-Well 2	06-Jan-25 14:09	8.8	---	0	0	---
11: RW RW4-Point Clark RW-Well 3	06-Jan-25 14:14	8.8	---	0	0	---
12: TW TW3-Point Clark TW	06-Jan-25 14:04	8.8	1.41	0	0	< 10
13: DW DW-Point Clark Community Centre	06-Jan-25 14:30	8.8	1.49	0	0	< 10
14: RW RW5-Murdoch Glen RW-Well	06-Jan-25 15:44	8.8	---	0	0	---
15: TW TW4-Murdoch Glen TW	06-Jan-25 15:45	8.8	1.52	0	0	< 10
16: RW RW2-Huronville South RW-Well 1	06-Jan-25 15:25	8.8	---	0	0	---
17: TW TW2-Huronville South TW	06-Jan-25 15:21	8.8	1.56	0	0	< 10
18: DW DW-Inverlyn Club House	06-Jan-25 16:02	8.8	1.36	0	0	< 10

MAC - Maximum Acceptable Concentration

### Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

  
**Cristal Schuster**  
 Project Specialist-London,



**SGS Canada Inc.**  
657 Consortium Court  
London - Ontario - N6E 2S8  
Phone: 519-672-4500 FAX: 519-672-0361

**Works #:** 220000425

**LR Report :** CA20301-JAN25

*Environment, Health & Safety*